

AMENDMENT NO. 1 SEPTEMBER 2025
TO
IS 18797 : 2024 PACKAGED SEWAGE TREATMENT PLANT —
SPECIFICATION

(Page 1, clause 3.12) — Insert the following at the end.

‘3.13 Acclimatization Period — It is the time taken to achieve normal process for testing and commissioning of any STP. Acclimatization is considered complete when the microorganisms are able to effectively degrade the organic matter in the wastewater, resulting in a stable removal rate and consistent performance of the STP.’

(Page 2, clause 4.3.1, line 4) — Insert the following at the end:

‘Size of the system is defined by its capacity to treat influent wastewater in kilolitres per day (KLD).’

[Page 3, Table 2, row 5, col (2)] — Substitute ‘Dissolved PO₄ as P’ for ‘Total phosphorus (TP)’.

[Page 3, Table 2, row 6] — Delete.

[Page 7, Clause 10.1, Sl No. (d)] — Substitute ‘kilolitres per day (KLD)’ for ‘litres and population equivalent’.

(Page 9, Clause B-1, line 4) — Substitute ‘12 months’ for ‘48 weeks’.

(Page 9, Clause B-1, line 5) — Substitute ‘2 months’ for ‘8 weeks’.

(Page 9, Clause B-4, line 7) — Substitute ‘of the value’ for ‘or more than the concentration’.

(Page 9, Clause B-5, line 8) — Substitute ‘10 months’ for ‘40 weeks’.

(Page 9, Clause B-5, line 9) — Substitute ‘1 month’ for ‘4 weeks’.

(Page 9, Clause B-5, line 10) — Substitute ‘1 month for a total of 12 months’ for ‘4 weeks for a total of 48 weeks’.

(Page 9, Clause B-6) — Substitute the following for the existing:

‘The assessor shall prepare and maintain a survey plan to measure the system performance with evaluation frequencies as described in [Table 7](#). Only the parameters listed in Table 1 are qualifying parameters for effluent. However, the tests given in [Table 7](#) are to be performed on both influent and effluent for parameters given in Table 6 and Table 1 respectively. The frequency of testing for influent and effluent shall remain the same. The method of sampling and physicochemical characterization of influent, effluent, and sludge at all stages of the assessment shall be in accordance with the relevant parts of the IS 3025 as specified in col (5) of [Table 7](#). The assessor shall also maintain records of any maintenance activities, level of sludge at the time of desludging, time taken for desludging, records for shut down period, lean period, replacement of filter/media/blower, etc.’

(Page 9, Clause B-7, line 4) — Substitute ‘minimum 12 with 10 from normal flow mode and a total of 2 from low and high flow modes’ for ‘minimum 48 with 40 from normal flow mode and a total of 8 from low and high flow modes’.

[Page 9, Table 6, row 2, col (2)] — Substitute ‘COD’ for ‘COD_{cr}’.

Amendment No. 1 to IS 18797 : 2024

(Page 10, Table 7) — Substitute the following for the existing:

‘Table 7 Parameters for Evaluation and Frequency of Testing

(Clause [B-6](#))

Sl No.	Parameter	Unit	Frequency	Method of Test, IS
(1)	(2)	(3)	(4)	(5)
i)	Daily influent flow	litres/day	As declared	—
ii)	Inflow period	hours/day	As declared	—
iii)	Inflow pattern	(%) v/s hour	As declared	—
iv)	Peak influent flow	litres/minute	As declared	—
v)	Temperature of influent	°C	As declared	—
vi)	Daily effluent flow	litres/day	As declared	—
vii)	Sludge level	metres	Monthly	—
viii)	Scum level	metres	Monthly	—
ix)	Biological/biochemical oxygen demand (BOD)	mg/l	Monthly	IS 3025 (Part 44)
x)	Chemical oxygen demand (COD)	mg/l	Monthly	IS 3025 (Part 58)
xi)	Total suspended solids (TSS)	mg/l	Monthly	IS 3025 (Part 17)
xii)	Total nitrogen (TN)	mg/l	Monthly	IS 3025 (Part 34)
xiii)	Dissolved PO ₄ as P	mg/l	Monthly	IS 3025 (Part 31/Sec 2)
xiv)	pH		Monthly	IS 3025 (Part 11)’

(Page 10, Footnote) — Delete.