

**AMENDMENT NO. 2 OCTOBER 2008
TO
IS 12776 : 2002 GALVANIZED STRAND FOR
EARTHING — SPECIFICATION**

(First Rrevision)

(Page 1, clause 8.1.1) — Add following at the end:

‘This is a Type Test.’

(Page 2, clause 8.1.3, first line) — Delete the word ‘Alternatively’.

(Page 2, clause 8.3.2, eighth line) — Substitute ‘20°C’ for ‘200°C’.

(Page 2, clause 8.6) — Add following new clause after 8.6.

‘8.7 Sample of wire shall be taken from lengths of each galvanized steel earth strand for the purpose of calculating tensile strength of the individual wires. Sample shall be taken from finished strand also for breaking force test of strand. The value of breaking force of individual wires and strand shall meet the requirement as specified in Annex A of the standard.’

(ME 10)

Reprography Unit, BIS, New Delhi, India