

AMENDMENT NO. 2 DECEMBER 2008
TO
IS 12800 (PART 2/SEC 1) : 1989 GUIDELINES FOR
SELECTION OF TURBINES, PRELIMINARY
DIMENSIONING AND LAYOUT OF SURFACE
HYDROELECTRIC POWER HOUSES

PART 2 PUMPED STORAGE POWER HOUSES

Section 1 Vertical Francis Runner

(Page 12, Annex A, clause A-2) — Substitute the following formula of Rated Pump Discharge, Q_p for the existing:

$$Q_p = \left[\frac{N_{sp} \times H_p^{3/4}}{n} \right]^2$$

(Page 12, Annex A, clause A-2) — Substitute 'Pump Input' for 'Pump Output'.