

AMENDMENT NO. 1 JUNE 2010
TO
IS 12820 : 2004 DIMENSIONAL REQUIREMENTS OF
RUBBER GASKETS FOR MECHANICAL JOINTS AND
PUSH-ON JOINTS FOR USE WITH CAST IRON PIPES
AND FITTINGS FOR CARRYING WATER, GAS AND
SEWAGE

(First Revision)

(Page 4, Table 5, col 3 against Dimension 'J') — Substitute '350 to 400'
for '350 to 300' and '450 to 600' for '450 to 400'

(MTD 6)

Reprography Unit, BIS, New Delhi, India