

AMENDMENT NO.1 OCTOBER 2004
TO
IS 13010 : 2002 ac WATTHOUR METERS,
CLASS 0.5, 1 AND 2 — SPECIFICATION

(First Revision)

(Page 5, clause 6.2.1) — Substitute the following for the existing:

‘The meter shall have a reasonably dust/moisture-proof case, which shall be sealed by the manufacturer in such a way that the internal parts of the meter are accessible only after breaking such distinctive seal(s).’

(Page 7, clause 6.6) — Substitute the following for the existing:

‘The terminal block, the terminal cover (if not of metal) and the case (if not of metal) shall be of a material which complies with the requirement of the test given in ISO 75 for a temperature of 135°C and a pressure of 1.8 MPa (Method A).

NOTE — If the materials of the terminal block, the terminal cover and the case meet this requirement the finished meter need not be tested.’