

AMENDMENT NO. 1 SEPTEMBER 2013
TO
IS 1838 (Part 3) : 2011 PREFORMED FILLERS FOR
EXPANSION JOINTS IN CONCRETE PAVEMENTS AND
STRUCTURES (NON-EXTRUDING AND RESILIENT
TYPE) — SPECIFICATION

PART 3 POLYMER BASED

[Page 2, Table 1, Sl No. (iii), col 3] — Substitute the following for the existing entry:

‘Load required to compress the specimen to 50 percent of its original thickness before the test shall be:

- a) 0.07 N/mm^2 , *Min*
- b) 10 N/mm^2 , *Max*’