

AMENDMENT NO. 1 DECEMBER 1984

TO

IS:2026(Part 4)-1977 SPECIFICATION FOR POWER
TRANSFORMERS

PART 4 TERMINAL MARKINGS, TAPPINGS
AND CONNECTIONS

(First Revision)

*(Page 12, clause 3.1.6) - Substitute the
following for the existing clause:*

"3.1.6 Requirements Related to Temperature-
Rise (Gurantees and Tests) - Temperature-rise
limit values are applicable to the tapping
position as specified in 3.4 of IS:2026(Part 2)
1977 'Specification for power transformers,
Part 2 Temperature-rise'. Except in such
cases where agreed to between the purchaser
and the supplier, the temperature-rise test
need be carried out on one tapping only,
chosen in accordance with 3.4 of IS:2026
(Part 2)-1977."

*(Page 12, clause 3.2.2.2, Note 2) -
Delete.*

(ETDC 16)