

AMENDMENT NO. 1 JULY 1997
TO
IS 2086 : 1993 CARRIERS AND BASES USED IN
REWIRABLE TYPE ELECTRIC FUSES FOR
VOLTAGES UP TO 650 V — SPECIFICATION
(Third Revision)

(*First cover page, Title*) — Insert 'Used' between the words ' BASES' and 'IN'.

(*Page 4, clause 7.1*) — Substitute the following for the existing clause:

'7.1 The dimensions of carriers and bases used in rewirable type electric fuses shall conform to Type A dimensions given in Annex A.'

(*Page 4, clauses 7.2 and 7.3*) — Delete.

(*Pages 12 and 14, Fig. 5A and 6A*) — Insert the following Note below both the figures:

'NOTE — Dimension 'a' is to be measured from the point where the carrier surface touches the base surface in assembled condition.'

(ET 39)