

AMENDMENT NO. 1 JULY 2024
TO
IS 10810 (PART 60) : 1988 METHODS OF TEST FOR CABLES
PART 60 THERMAL STABILITY OF PVC INSULATION AND SHEATH

(*Page 1, clause 8.4*) — Substitute the sentence ‘The universal indicating paper shall be renewed towards the end of the expected test time 5 to 10 minutes, so that the change point is better visible.’ *for* ‘The universal indicating paper shall be renewed (specially for long duration stabilities) towards the end of the expected test time every 5 to 10 minutes, so that the change point is better visible.’

(ETD 09)

Price Group 1

Publication, BIS, New Delhi