

**AMENDMENT NO. 1 MARCH 2004
TO
IS 10810 (PART 61) : 1988 METHODS OF TEST
FOR CABLES**

PART 61 FLAME RETARDANT TEST

(Page 1, clause 6.2, second para) — Substitute the following for the existing:

'The external diameter of the test specimen shall not exceed 35 mm.'

(ET 09)

Reprography Unit, BIS, New Delhi, India