

**AMENDMENT NO. 7 AUGUST 1995
TO
IS 2312 : 1967 SPECIFICATION FOR PROPELLER
TYPE ac VENTILATING FANS**

(First Revision)

(Page 10, clause **14.2**) — Add the following matter after this clause:

'The fan shall be mounted so as to keep the mounting of the fan impeller (blades) flush with the plane of fan casing end of the test duct.'

(Page 17, clause **14.6**) — Add the following matter after this clause:

'c) 0.50 for fans operated on 3 phase 400 V or 415 V 50 Hz supply and rated input not exceeding 50 watts.'

(ETD 5)

Printed at New India Printing Press, Khurja, India