

AMENDMENT NO. 1 MARCH 2024
TO
IS 15155 : 2020 BAR/WIRE WRAPPED STEEL CYLINDER PIPES WITH MORTAR
LINING AND COATING (INCLUDING SPECIALS) — SPECIFICATION
(First Revision)

(Page 1, clause 4.2, line 8) — Substitute the word ‘sand’ for ‘srand’.

(Page 3, clause 5.2.4, informal table) — Substitute the following table for the existing:

All Diameters	<i>Socket Ring</i>	<i>Spigot Ring</i>
	+ 8.5, - 1.5	+ 1.5, - 8.5

(Page 3, clause 5.2.5, informal table) — Substitute the following table for the existing:

All Diameters	<i>Socket Ring</i>	<i>Spigot Ring</i>
	+ 7, - 3	+ 3, - 7

(Page 10, clause C-3, line 2) — Substitute the following for the existing:

‘Site test pressure, $P_s = (P_w \times 1.5) = 1.176\ 8\ \text{N/mm}^2$ ’.

[Page 11, clause C-3.1 (c)] — Substitute the following formula for the existing:

$$A_{st} = \frac{P_w \times D_{yi}}{2 \times f_{sw}}$$

[Page 12, clause C-3.4.1(b)] — Substitute the following formula for the existing:

$$F_a = \frac{1.176\ 8 \times 1035}{2 \times 3.700} = 164.59\ \text{N/mm}^2.$$

[Page 12, clause C-3.4.1(c)] — Substitute the following formula for the existing:

$$F_a = \frac{0.784\ 5 \times 1\ 035}{2 \times 3.700} = 109.72\ \text{N/mm}^2.$$

(Page 13, clause C-3.6.2.2, para 2, first sentence) — Substitute the following for the existing:

‘First moment AY and moment of Inertia $\bar{I}_x$ are taken about X-axis.’