

AMENDMENT NO. 2 APRIL 2022

TO

**IS 15259 : 2002 INSTALLATION AND MAINTENANCE
OF HOME LIFTS — CODE OF PRACTICE**

(Page 2, clause 5.6) — Substitute the following for the existing clause:

‘5.6 Suspension; Sheaves and Pulleys

5.6.1 *Suspension*

Where provided, the suspension shall comply with the requirements specified in the 7 of Section 3 of IS 14665 (Part 4/Sec 1 to 9) except that the number of independent suspension ropes shall not be less than three for 8 mm diameter ropes.

5.6.2 *Sheaves and Pulleys*

The sheaves and pulleys shall comply with the requirements specified in the 8 of Section 3 of IS 14665 (Part 4/Sec 1 to 9) except that the ratio between pitch diameter of the sheaves and the nominal diameter of the suspension ropes shall be minimum 25.’