

AMENDMENT NO. 1 DECEMBER 2022

TO

**IS 15450 : 2022 POLYETHYLENE-ALUMINIUM-POLYETHYLENE COMPOSITE
PRESSURE PIPES FOR HOT AND COLD WATER SUPPLIES — SPECIFICATION**

(First Revision)

(Foreward, last para) — Substitute ‘IS 2 : 2022 Rules for rounding off numerical values (*second revision*)’
for ‘IS 2 : 1960 Rules for rounding off numerical values (revised)’.

[Page 4, Table 3, *Sl No. i*)] — Substitute the following for the existing:

SI No.	Characteristic	Unit	Requirement	Test Parameter	Method of Test, Ref to	
					IS No.	Annex
(1)	(2)	(3)	(4)	(5)	(6)	(7)
i)	Base Density	kg/m ³	940 to 960	27 °C	IS 7328	—

(CED 50)

Publication Unit, BIS, New Delhi, India