

**AMENDMENT NO. 1 SEPTEMBER 2007  
TO  
IS 15517 : 2004 GASEOUS FIRE EXTINGUISHING  
SYSTEMS — HFC 227<sub>ea</sub> (HEPTA FLUORO  
PROPANE) EXTINGUISHING SYSTEMS**

(Page 1, Table 1, col 2) — Substitute 'Hepta Fluoro Propane – ,1,1,2,3,3,3' for 'Hepta Fluoro Propane'.

[Page 2, clause 4.7, Table 4, Sl No. (iii), col 3] — Substitute '>80%' for '>80'.

[Page 2, clause 4.8, Table 5, Sl No. (i), col 3 and 4] — Substitute '1 150 g/m<sup>3</sup>' for '1.15 kg/m<sup>2</sup>'.

[Page 3, clause 5.1(d)] — Insert the following matter at the end:

- e) HFC 227<sub>ea</sub> system for spaces that are normally occupied and designed to concentrations above the NOAEL shall be permitted, if means are provided to limit exposure to the design concentrations shown in Table 8(b).'

(Page 3, Fig. 1) — Substitute 'S = 0.1269+0.0005' for 'S = 0.12632 + 0.000514'.

(Page 4, clause 6, lines 6 and 7) — Substitute 'IS 15493 : 2004' for 'relevant specifications'.

(Page 5 Table 8) — Renumber the existing Table 8 as '8A' and insert the following Table 8B:

Amend No. 1 to IS 15517 : 2004

Table 8B Time for Safe Human Exposure at Stated Concentration  
for HFC 227ea

[Clause 5.1(e)]

| HFC 227ea Concentration |         | Human Exposure Time |
|-------------------------|---------|---------------------|
| Percent, w/v            | ppm     | (Min)               |
| 9.0                     | 90 000  | 5.00                |
| 9.5                     | 95 000  | 5.00                |
| 10.0                    | 100 000 | 5.00                |
| 10.5                    | 105 000 | 5.00                |
| 11.0                    | 110 000 | 1.13                |
| 11.5                    | 115 000 | 0.60                |
| 12.0                    | 120 000 | 0.49                |

NOTE — Data derived from EPA approved and peer-reviewed PBPK model or its equipment.

[Page 7, clause 8(e)(1)] — Substitute ‘Design concentration’ for ‘Minimum concentration’.

[Page 7, clause 8(e)(2), line 6] — Substitute safety factor ‘20 percent’ for ‘10 percent’.

(Page 7, Table 10, col 3) — Substitute the following for the existing:

| Percent by Volume |    |       |
|-------------------|----|-------|
| (3)               |    |       |
| 6.2               | to | 7.0   |
| 7.6               | to | 11.05 |
| 7.15              | to | 8.0   |
| 9.9               | to | 13.52 |
| 8.0               | to | 8.6   |
| 8.6               | to | 8.71  |

(CED 22)