

AMENDMENT NO. 2 JANUARY 2009
TO
IS 15517 : 2004 GASEOUS FIRE EXTINGUISHING SYSTEMS — HFC 227ea
(HEPTA FLUORO PROPANE) EXTINGUISHING SYSTEMS

(Page 1, clause 4.5, line 3) — Substitute ‘HFC 227ea’ for ‘HFC Lea’.

(Page 2, clause 4.6, Table 3):

a) *Sl No.* (iii) — Substitute ‘– 131.1°C’ for ‘<131.1°C’.

b) *Sl No.* (iv) — Substitute ‘(absolute)’ for ‘0.391 MPa’.

(Page 2, Table 4, col. 3) — Against the values of NOAEL, LOAEL and LC₅₀, add the words ‘by volume’ against each and against LC₅₀, add the word ‘percent’ also.

[Page 2, Table 5, *Sl No.* (i)] — Substitute the following for the existing:

Sl No.	Property	Values	
		2.5 MPa	4.2 MPa
(1)	(2)	(3)	(4)
i)	Maximum fill density	1 150 kg/m ³	1 150 kg/m ³

(Page 5, clause 7.2(a) — Substitute ‘*t*’ for ‘*T*’.

where ‘*t*’ is the minimum anticipated temperature in °C inside the enclosure intended to be protected.

(Page 5, clause 7.3) — Delete ‘*V_s*’ and its corresponding definition.