

AMENDMENT NO. 1 FEBRUARY 2012
TO
IS 15549 : 2005 STATIONARY VALVE REGULATED LEAD
ACID BATTERIES — SPECIFICATION

(Page 4, clause 12.1, line 26 from top, formula) – Substitute

$$‘C_t + \frac{[C_t \times R (27-t)]}{100} \text{ for } \frac{‘C_t + [C_t \times R (27-t)]’}{100}$$

(ET 11)

Reprography Unit, BIS, New Delhi, India