

AMENDMENT NO. 2 DECEMBER 2014
TO
IS 15549 : 2005 STATIONARY VALVE REGULATED LEAD
ACID BATTERIES — SPECIFICATION

(Page 3, clause 10.1.2) — Substitute ‘Type test shall be carried out on six (6) cells. Refer to sequence of type testing given in Table 3’ for ‘Type tests shall be carried out on seven (7) cells. Refer to sequence of type testing given in Table 3’

(Page 4, clause 12.2, para 4) — Insert the following text at the end of para 4:

‘However, for discharge rates higher than C5 (C1 to C4), the average temperature measurement shall be made from the cell container surface’.

(Page 5, clause 12.4) — Substitute ‘Requirement: The Ampere hour (Ah) efficiency when calculated as above shall not be less than 95 percent’ for ‘Requirement: The Ampere hour (Ah) efficiency when calculated as above shall not be less than 90 percent.’

(Page 5, clause 12.5) — Substitute ‘Requirement: The Watt hour (Wh) efficiency when calculated as above shall not be less than 85 percent’ for ‘Requirement: Watt hour (Wh) efficiency when calculated as above shall not be less than 80 percent.’

(Page 6, clause 12.9) — Substitute ‘Requirement: The gas recombination efficiency shall not be less than 95 percent’ for ‘Requirement: The gas recombination efficiency shall not be less than 90 percent.’

(Page 6, clause 12.10, para 1, para 2) — Substitute ‘Discharge the cell/battery at $1 = 0.24 \times C_{10}$ Amperes to an end voltage of 1.74 V (Equivalent to C3 capacity)’ for ‘Discharge the cell/battery at $1 = 2.4 \times C_{10}$ Amperes to an end voltage of 1.74 V (Equivalent to C3 capacity)’

(Page 6, clause 12.10, para 2, para 3) — Substitute ‘The cell/battery shall be discharged for 3 h at the rate of $1 = 0.192 \times C_{10}$ followed by charge at constant voltage of 2.33 V/cell and with current limit of 40 percent of its rated capacity for duration of 9 h’ for ‘The cell/battery shall be discharged for 3 h at the rate of $1 = 1.92 \times C_{10}$ followed by charge at constant voltage of 2.33 V/cell and with current limit of 40 percent of its rated capacity for duration of 9 h.’