

AMENDMENT NO. 3 JUNE 2018
TO
IS 15549 : 2005 STATIONARY VALVE REGULATED LEAD
ACID BATTERIES — SPECIFICATION

(Page 1, clause 4.2) — Insert the following text at the end of clause:

‘The bulging of container should not be greater than 5 percent (in dimensions) on any side of the cell/battery.’

(ETD 11)

Publication Unit, BIS, New Delhi, India