

AMENDMENT NO. 4 JULY 2025
TO
IS 11329 : 2018 FINNED TYPE HEAT EXCHANGER FOR ROOM AIR
CONDITIONER
(*First Revision*)

(Page 2, Fig. 3) — Delete.

[Page 3, clause **5.1**, a) (*see also Amendment No. 1 and 2*)] — Substitute the following for the existing:

‘a) *Copper tube* — Copper tube shall conform to IS 10773 or IS 1545 or as per the requirements listed in Annex B. Dimensions and tolerances of the tubes if not specified, shall be as agreed to between manufacturer and purchaser.’

[Page 4, clause **5.3**, b) (*see also Amendment No. 1*)] — Substitute the following for the existing:

‘b) *Aluminium sheet* — Aluminium sheet material shall conform to **7** of IS 737 for chemical composition and Annex C.’

[Page 9, Annex A (*see also Amendment No.3*)] — Substitute the following for the existing at appropriate place:

‘IS 1545 : 1994 Solid drawn copper and copper alloy tubes for condensers and heat exchangers — Specification (*third revision*)’

[Page 9, clause **B-1** (*see also Amendment No. 2*)] — Substitute the following for the existing:

‘Sl No.	Elements	C12200/C1220T Grade	C1020 Grade
(1)	(2)	(3)	(4)
i)	Cu	99.90 <i>Min</i>	99.96 <i>Min</i>
ii)	Pb	—	—
iii)	Sn	—	—
iv)	Fe	—	—
v)	Al	—	—
vi)	Mn	—	—
vii)	As	—	—
viii)	Ni	—	—
ix)	Zn	—	—
x)	P	0.015 to 0.040	—’

(MED 03)

Price Group 1
Publication, BIS, New Delhi