

AMENDMENT NO. 5 OCTOBER 2025
TO
IS 11329 : 2018 FINNED TYPE HEAT EXCHANGER FOR ROOM AIR
CONDITIONER
(*First Revision*)

[Page 9, clause **B-1** (see also Amendment No. 2 and Amendment No. 4)] — Substitute the following for the existing:

<i>'Sl No.</i>	<i>Elements</i>	<i>C12200/C1220T Grade</i>	<i>C1020 Grade</i>	<i>Copper Alloy No.3</i>
(1)	(2)	(3)	(4)	(5)
i)	Cu	99.90 <i>Min</i>	99.96 <i>Min</i>	99.20 <i>Min</i>
ii)	Pb	—	—	—
iii)	Sn	—	—	0.60 <i>Max</i>
iv)	Fe	—	—	—
v)	Al	—	—	—
vi)	Mn	—	—	—
vii)	As	—	—	—
viii)	Ni	—	—	0.20 <i>Max</i>
ix)	Zn	—	—	—
x)	P	0.015 to 0.040	—	0.035 <i>Max</i>
xi)	O	—	—	0.01 <i>Max'</i>

(MED 03)

Price Group 1
Publication, BIS, New Delhi