

AMENDMENT NO. 1 JUNE 2001
TO
IS 456 : 2000 PLAIN AND REINFORCED CONCRETE — CODE OF PRACTICE
(Fourth Revision)

(Page 2, Foreword, last but one line) — Substitute 'ACI 318 : 1995' for 'ACI 318 : 1989'.

(Page 11, clause 4) — Delete the matter 'L_w — Horizontal distance between centres of lateral restraint'.

(Page 15, clause 5.5, Title) — Substitute 'Chemical Admixtures' for 'Admixtures'.

(Page 17, clause 7.1) — Substitute the following for the existing informal table:

Placing Conditions	Degree of Workability	Slump (mm)
(1)	(2)	(3)
Blinding concrete; Shallow sections; Pavements using pavers	Very low	See 7.1.1
Mass concrete; Lightly reinforced sections in slabs, beams, walls, columns; Floors; Hand placed pavements; Canal lining; Strip footings	Low	25-75
Heavily reinforced sections in slabs, beams, walls, columns;	Medium	50-100
Slipform work; Pumped concrete	Medium	75-100
Trench fill; In-situ piling	High	100 -150
Tremie concrete	Very high	See 7.1.2

NOTE — For most of the placing conditions, internal vibrators (needle vibrators) are suitable. The diameter of the needle shall be determined based on the density and spacing of reinforcement bars and thickness of sections. For tremie concrete, vibrators are not required to be used (see also 13.3).

(Page 19, Table 4, column 8, sub-heading) — Substitute 'Free' for 'Face' .

(Page 27, clause 13.5.3) — Delete.

(Page 29, clause 15.3):

a) Substitute 'specimens' for 'samples' in lines 2, 6 and 7.

b) Substitute 'IS 9013' for 'IS 9103' .

(Page 29, clause 16.1) — Substitute 'conditions' for 'condition' in line 3 and the following matter for the existing matter against 'a)' :

'a) The mean strength determined from any group of four non-overlapping consecutive test results complies with the appropriate limits in column 2 of Table 11.'

(Page 29, clause 16.3, para 2) — Substitute 'col 3' for 'col 2'.

(Page 29, clause 16.4, line 2) — Substitute '16.1 or 16.2 as the case may be' for '16.3'.

(Page 30, Table 11, column 3) — Substitute ' $\geq f_{ck} - 3$ ' for ' $\geq f_{ck}^{-3}$ ' and ' $\geq f_{ck} - 4$ ' for ' $\geq f_{ck}^{-4}$ '.

Amend No. 1 to IS 456 : 2000

(Page 33, clause 21.3, line 2) — Substitute 'section' for 'section'.

[Page 37, clause 23.1.2(c)] — Substitute 'b_f' for 'b', 'l₀' for 'l₀', 'b' for 'b' and 'b_w' for 'b_w' in the formulae.

(Page 46, clause 26.4.2) — Substitute '8.2.2' for '8.2.3'.

[Page 49, clause 26.5.3.2 (c) (2), last line] — Substitute '6 mm' for '16 mm'.

(Page 62, clause 32.2.5) — Substitute 'H_w²' for 'H_w' in the explanation of e_s.

(Page 62, clause 32.3.1, line 4) — Substitute '32.4' for '32.3'.

[Page 62, clause 32.4.3 (b), line 6] — Insert 'τ_{ew}' between the words 'but' and 'shall'.

[Page 65, clause 34.2.4.1(a), last line] — Insert the following after the words 'depth of footing' :

'in case of footings on soils, and at a distance equal to half the effective depth of footing'.

(Page 68, Table 18, col 4) — Substitute '-' for '1.0' against the Load Combination DL + IL.

(Page 72, clause 40.1) — Substitute 'bd' for 'b_d' in the formula.

(Page 83, clause B-4.3, line 2) — Delete the word 'and' .

(Page 85, clause B-5.5.1, para 2, line 6) — Substitute 'Table 24' for 'Table 23'.

(Page 85, clause B-5.5.2) — Substitute the following for the existing formula:

$$A_s = a_s b (\tau_v - 2d \tau_c / a_s) / \sigma_{sv} \geq 0.4 a_s b / 0.87 f_y$$

(Page 90, clause D-1.11, line 1) — Substitute 'Where' for 'Torsion'.

(Page 93, Fig. 27) — Substitute 'l_e/l' for 'l/L'.

(Page 95, Annex F):

a) The reference to Fig. 28 given in column 1 of the text along with the explanation of the symbols used in the Fig. 28 given thereafter may be read just before the formula given for the rectangular tension zone.

b) Substitute 'compression' for 'campression' in the explanation of symbol 'a' .

(Pages 98 to 100, Annex H) — Substitute the following for the existing Annex :

ANNEX H

(Foreword)

COMMITTEE COMPOSITION

Cement and Concrete Sectional Committee, CED 2

Chairman

DR H. C. VISVESVARAYA
'Chandrika', at 15th Cross, 63-64 East Park Road,
Mallewaram, Bangalore-560 003

Representing

Members

DR S. C. AHLUWALIA

SHRI V. BALASUBRAMANIAN

SHRI R. P. SINGH (Alternate)

SHRI G. R. BHARITKAR

SHRI A. K. CHADHA

SHRI J. R. SIL (Alternate)

CHIEF ENGINEER (DESIGN)

SUPERINTENDING ENGINEER (S&S) (Alternate)

CHIEF ENGINEER (NAVAM DAM)

SUPERINTENDING ENGINEER (QCC) (Alternate)

CHIEF ENGINEER (RESEARCH)-CUM-DIRECTOR

RESEARCH OFFICER (CONCRETE TECHNOLOGY)
(Alternate)

OCL India Ltd, New Delhi

Directorate General of Supplies and Disposals, New Delhi

B. G. Shirke Construction Technology Ltd, Pune

Hindustan Prefab Limited, New Delhi

Central Public Works Department, New Delhi

Sardar Sarovar Narmada Nigam Ltd, Gandhinagar

Irrigation and Power Research Institute, Amritsar

Amend No. 1 to IS 456 : 2000

(Continued from page 2)

<i>Members</i>	<i>Representing</i>
SHRI J. P. DESAI SHRI B. K. JAGTIA (Alternate)	Gujarat Ambuja Cements Ltd, Ahmedabad
DIRECTOR JOINT DIRECTOR (Alternate)	A.P. Engineering Research Laboratories, Hyderabad
DIRECTOR (CMD) (N&W) DEPUTY DIRECTOR (CMD) (NW&S) (Alternate)	Central Water Commission, New Delhi
SHRI K. H. GANGWAL SHRI V. PATTABHI (Alternate)	Hyderabad Industries Ltd, Hyderabad
SHRI V. K. GHANEKAR	Structural Engineering Research Centre (CSIR), Ghaziabad
SHRI S. GOPINATH SHRI R. TAMILAKARAN (Alternate)	The India Cements Ltd, Chennai
SHRI S. K. GUHA THAKURTA SHRI S. SANKARANARAYANAN (Alternate)	Gannon Dunkerley and Company Ltd, Mumbai
SHRI N. S. BHAL DR IRSHAD MASOOD (Alternate)	Central Building Research Institute (CSIR), Roorkee
PROF A. K. JAIN	University of Roorkee, Roorkee
SHRI N. C. JAIN	Cement Corporation of India Ltd, New Delhi
JOINT DIRECTOR (STANDARDS) (B&S) (CB-I) JOINT DIRECTOR (STANDARDS) (B&S) (CB-II) (Alternate)	Research, Designs & Standards Organization (Ministry of Railways), Lucknow
SHRI N. G. JOSHI SHRI P. D. KELKAR (Alternate)	The Indian Hume Pipe Company Ltd, Mumbai
SHRI D. K. KANUNGO SHRI B. R. MEENA (Alternate)	National Test House, Calcutta
SHRI P. KRISHNAMURTHY SHRI S. CHOWDHURY (Alternate)	Larsen & Toubro Ltd, Mumbai
DR A. G. MADHAVA RAO SHRI K. MANI (Alternate)	Structural Engineering Research Centre (CSIR), Chennai
SHRI J. SARUP	Hospital Services Consultancy Corporation (India) Ltd, New Delhi
SHRI V. SURESH SHRI D. P. SINGH (Alternate)	Housing and Urban Development Corporation Ltd, New Delhi
SHRI PRAFULLA KUMAR SHRI P. P. NAIR (Alternate)	Ministry of Surface Transport, Department of Surface Transport (Roads Wing), New Delhi
MEMBER SECRETARY DIRECTOR (CIVIL) (Alternate)	Central Board of Irrigation & Power, New Delhi
SHRI S. K. NATHANI DR A. S. GOEL (Alternate)	Engineer-in-Chief's Branch, Army Headquarters, New Delhi
SHRI S. S. SEEHRA SHRI SATINDER KUMAR (Alternate)	Central Road Research Institute (CSIR), New Delhi
SHRI Y. R. PHULL SHRI A. K. SHARMA (Alternate)	Indian Roads Congress, New Delhi
DR C. RAJKUMAR DR K. MOHAN (Alternate)	National Council for Cement and Building Materials, Ballabgarh
SHRI S. A. REDDI	Gammon India Ltd, Mumbai
REPRESENTATIVE	Builder's Association of India, Mumbai
SHRI J. S. SANGANERIA SHRI L. N. AGARWAL (Alternate)	Geological Survey of India, Calcutta
SUPERINTENDING ENGINEER (DESIGN) EXECUTIVE ENGINEER (SMR DIVISION) (Alternate)	Public Works Department, Government of Tamil Nadu, Chennai
SHRI K. K. TAPARIA SHRI A. K. JAIN (Alternate)	Indian Rayon and Industries Ltd, Pune
SHRI T. N. TIWARI DR D. GHOSH (Alternate)	The Associated Cement Companies Ltd, Mumbai
DR K. VENKATACHALAM SHRI N. CHANDRASEKARAN (Alternate)	Central Soil and Materials Research Station, New Delhi

Amend No. 1 to IS 456 : 2000

(Continued from page 3)

Members

DR H. C. VINAYAKAYA
SHRI D. C. CHATURVEDI (Alternate)
SHRI VINOD KUMAR
Director (Civ Engg)

Representing

The Institution of Engineers (India), Calcutta
Director General, BIS (Ex-officio Member)

Member-Secretaries

SHRI J. K. PRASAD
Additional Director (Civ Engg), BIS
SHRI SANJAY PANT
Deputy Director (Civ Engg), BIS

Concrete Subcommittee, CED 2:2

Convener

DR A. K. MULLICK

Representing

National Council for Cement and Building Materials, Ballabgarh

Members

SHRI C. R. ALIMCHANDANI
SHRI S. RANGARAJAN (Alternate)
DR P. C. CHOWDHURY
DR C. S. VISHWANATHA (Alternate)
SHRI J. P. DESAI
SHRI B. K. JAGTIA (Alternate)
DIRECTOR
SHRI N. CHANDRASEKARAN (Alternate)
DIRECTOR (C&MDD)
DEPUTY DIRECTOR (C&MDD) (Alternate)
JOINT DIRECTOR STANDARDS (B&S)/CB-II
JOINT DIRECTOR STANDARDS (B&S)/CB-I
(Alternate)
SUPERINTENDING ENGINEER (DESIGNS)
EXECUTIVE ENGINEER (DESIGNS)-III (Alternate)
SHRI V. K. GHANEKAR
SHRI D. S. PRAKASH RAO (Alternate)
SHRI S. K. GUHA THAKURTA
SHRI S. P. SANKARANARAYANAN (Alternate)
SHRI J. S. HINGORANI
SHRI L. K. JAIN
SHRI M. P. JAISINGH
DR B. KAMESWARA RAO (Alternate)
CHIEF ENGINEER & JOINT SECRETARY
SUPERINTENDING ENGINEER (Alternate)
PROF S. KRISHNA MOORTHY
SHRI K. K. NAYAR (Alternate)
DR S. C. MAITI
MANAGING DIRECTOR
SHRI M. KUNDU (Alternate)
SHRI S. K. NAITHANI
LT-COL K. S. CHABAK (Alternate)
SHRI B. V. B. PAJ
SHRI M. G. DANDVATE (Alternate)
SHRI A. B. PHADKE
SHRI D. M. SAVUR (Alternate)
SHRI Y. R. PHULL
SHRI S. S. SEHRA (Alternate I)
SHRI SATINDER KUMAR (Alternate II)

Stup Consultants Ltd, Mumbai
Torsteel Research Foundation in India, Calcutta
Gujarat Ambuja Cements Ltd, Ahmedabad
Central Soil and Materials Research Station, New Delhi
Central Water Commission, New Delhi
Research, Designs and Standards Organization (Ministry of Railways), Lucknow
Central Public Works Department, New Delhi
Structural Engineering Research Centre (CSIR), Ghaziabad
Gannon Dunkerley and Co Ltd, Mumbai
Associated Consulting Services, Mumbai
In personal capacity
Central Building Research Institute (CSIR), Roorkee
Public Works Department, Mumbai
Indian Institute of Technology, New Delhi
National Council for Cement and Building Materials, Ballabgarh
Hindustan Prefab Limited, New Delhi
Engineer-in-Chief's Branch, Army Headquarters, New Delhi
The Associated Cement Companies Ltd, Mumbai
The Hindustan Construction Co Ltd, Mumbai
Central Road Research Institute (CSIR), New Delhi

Amend No. 1 to IS 456 : 2000

(Continued from page 4)

<i>Members</i>	<i>Representing</i>
SHRI A. S. PRASAD RAO SHRI K. MANI (Alternate)	Structural Engineering Research Centre (CSIR), Chennai
SHRI K. L. PRUTHI SHRI J. R. GABRIEL (Alternate)	National Building Construction Corporation Ltd, New Delhi
SHRI B. D. RAHALKER SHRI U. S. P. VERMA (Alternate)	Nuclear Power Corporation, Mumbai
SHRI HANUMANTHA RAO SHRI G. RAMAKRISHNAN (Alternate)	A.P. Engineering Research Laboratories, Hyderabad
SHRI S. A. REDDI DR N. K. NAYAK (Alternate)	Gammon India Ltd, Mumbai
SHRI S. C. SAWHNEY SHRI R. P. MEHROTRA (Alternate)	Engineers India Ltd, New Delhi
PROF M. S. SHETTY	Indian Concrete Institute, Chennai
SHRI N. K. SINHA	Ministry of Surface Transport (Roads Wing), New Delhi
SHRI B. T. UNWALLA	In personal capacity

Panel for Revision of IS 456, CED 2:2/P

<i>Convener</i>	<i>Representing</i>
DR C. RAJKUMAR	National Council for Cement and Building Materials, Ballabgarh
<i>Members</i>	
DR ANIL KUMAR	National Council for Cement and Building Materials, Ballabgarh
SHRI V. K. GHANEKAR	Structural Engineering Research Centre (CSIR), Ghaziabad
PROF A. K. JAIN	University of Roorkee, Roorkee
SHRI L. K. JAIN	In personal capacity
SHRI JOSE KURIAN	Central Public Works Department, New Delhi
DR S. C. MAITI	National Council for Cement and Building Materials, Ballabgarh
DR A. K. MITTAL	Central Public Works Department, New Delhi
SHRI S. A. REDDI	Gammon India Ltd, Mumbai
DR V. THIRUVENGODAM	School of Planning and Architecture, New Delhi

Special Ad-Hoc Group for Revision of IS 456

<i>Convener</i>	<i>Representing</i>
DR H. C. VISVESVARAYA 'Chandrika', at 15 th Cross, 63-64 East Park Road, Malleswaram, Bangalore-560 003	
<i>Members</i>	
DR C. RAJKUMAR	National Council for Cement and Building Materials, Ballabgarh
SHRI S. A. REDDI	Gammon India Ltd, Mumbai

(CED 2)