

AMENDMENT NO. 6 JANUARY 1993
TO
IS 731 : 1971 SPECIFICATION FOR PORCELAIN
INSULATORS FOR OVERHEAD POWER LINES WITH
A NOMINAL VOLTAGE GREATER THAN 1 000 V

(*Second Revision*)

(*Page 22, clause 10.15.5*) — Add the following sentence to the clause:

'Streamer pattern formed during routine electrical tests may be observable, but it shall not disqualify the insulator for acceptance.'

(*Page 29, Table 5*) — Add the following note to the table:

"NOTE — Sample size for Type A insulators can be as per Table 3 of IS 2544 : 1973*."

(*Page 29, foot-note*) — Add the following foot-note:

"*Porcelain post insulators for systems with nominal voltage greater than 1 000 V (*first revision*)."

(ET 06)