

**AMENDMENT NO. 1 MAY 2005
TO
IS 13694 : 1993 FIRE SAFETY IN IRON AND
STEEL INDUSTRIES — CODE OF PRACTICE**

(*Page 5, clause 11.2.3*) — Substitute the following for the existing clause:

‘Clean Agents System — These systems are alternate to halon systems.’

(CED 36)

Reprography Unit, BIS, New Delhi, India