

AMENDMENT NO. 1 JANUARY 1981
TO
IS : 1569-1976 SPECIFICATION FOR CAPACITORS
FOR USE IN TUBULAR FLUORESCENT, HIGH
PRESSURE MERCURY AND LOW PRESSURE
SODIUM VAPOUR DISCHARGE
LAMP CIRCUITS

(First Revision)

Alterations

[Page 8, clause 4.1 (h) and (j)] — Substitute the following for the existing matter:

“h) Rated minimum and maximum temperatures, for example, 10/70°C;

j) If a capacitor is self-healing, the symbol ‘Sp’ or  ;
and ”.

(Page 12, clause 5.11) — Substitute the following for the existing clause:

“**5.11 Self-Healing Test** — This test shall be applied only to capacitors marked ‘Sp’ or  [see 4.1 (j)].”

(ETDC 23)