

AMENDMENT NO. 2 DECEMBER 2019

TO

**IS 1571 : 2018 AVIATION TURBINE FUELS,
KEROSENE TYPE, JET-A-1 SPECIFICATION**

(Tenth Revision)

[Page 6, Table No. 1, Sl No. vi)] — Substitute the following for the existing:

Sl No.	Characteristic	Requirement	Method of Test, Ref to [P:] of IS 1448/ ASTM/IP/ISO
(1)	(2)	(3)	(4)
vi)	Corrosion:		
	a) Copper strip corrosion for 2 h at 100°C	Not worse than No. 1	[P : 15]* / IP 154/ ASTM D 130
	b) Silver stripcorrosion ¹²⁾ classification, for 4 h at 50°C, Max	1	Annex B