

AMENDMENT NO. 1 JUNE 2026
TO
IS 1651 : 2013 STATIONARY CELLS AND BATTERIES, LEAD-ACID TYPE (WITH
TUBULAR POSITIVE PLATES) — SPECIFICATION
(Fourth Revision)

(Page 2, clause 5.1) — Substitute the following with the existing:

‘5.1 Containers

The containers shall be made of hard rubber, plastics (including transparent SAN polymer), fibre reinforced plastics for NDP, HDP cells.

For TBS cells, the container shall be made of transparent SAN polymer.

5.1.1 Hard rubber, plastics (including fibre-reinforced plastic (ERP) and transparent SAN polymer) containers shall conform to IS 1146.’

(Page 5, clause 12.1.1) — Delete.

(Page 5, clause 12.1.2, Heading) — Substitute the heading with the existing:

‘12.1.2 Type Tests for NDP, HDP, TBS Cells’

[Page 5, clause 12.1.2, (d)] — Substitute the following with the existing:

‘d) Test for capacity

- 1) Test for C₁₀ capacity (*see 12.5*) Test for voltage during discharge (*see 12.10*)
- 2) Test for C₁ capacity (*see 12.5*) and Test for voltage during discharge (*see 12.10*). ’

(Page 5, clause 12.1.3) — Delete.

(Page 5, clause 12.1.4) — Substitute the following with the existing:

‘For conducting type tests for NDP, HDP and TBS cells, formed positive plates along with components for the eight cells shall be chosen at random.

The selected cells shall undergo the different type tests as per the schedule given in Table 5.’

(Page 6, Table 4) — Delete.

(Page 6, Table 5, Heading) — Substitute the heading with the existing:

‘Table 5 Type Tests Schedule for NDP, HDP, TBS Cells’