

AMENDMENT NO. 1 DECEMBER 2024
TO
IS 1652 : 2013 STATIONARY CELLS AND BATTERIES, LEAD-ACID TYPE WITH
PLANTE POSITIVE PLATES — SPECIFICATION
(Fourth Revision)

(Page 1, clause 5.5.3, para 1) — This para shall be kept in abeyance.

(Page 2, clause 5.5.3, para 2) — This para shall be kept in abeyance.

(Page 2, clause 5.5.3, para 2) — Insert the following new para:

‘The clearance on bottom shall be measured from the highest moulded inside point at the bottom of the container to the bottom of the plate. The clearance on the side shall be measured from highest moulded inside point at the side of the container to the side of the plate.’

(ETD 11)

Price Group 1
Publication, BIS, New Delhi