

AMENDMENT NO. 2 DECEMBER 1993
TO
IS 1785 (Part 1) : 1983 SPECIFICATION FOR PLAIN
HARD-DRAWN STEEL WIRE FOR PRESTRESSED
CONCRETE

PART 1 COLD-DRAWN STRESS - RELIEVED WIRE

(Second Revision)

(*Page 4, clause 2.1*) — Delete and renumber the subsequent clauses as **2.1** to **2.5**.

(*Page 5, clause 5.1.1*) — Add new clause **5.1.2** as follows:

'5.1.2 Where the diameter measurements (taken in two directions at right angles in the same plane) show an ovality of not more than half of the total diameter tolerance, no checks on section by weighing shall be necessary. Where ovality is more than half of the total diameter tolerance, check on section by weighing shall be made. Nominal mass and tolerance on nominal mass of the finished wire shall be as given below:

<i>Nominal Diameter</i>	<i>Nominal mass</i>	<i>Tolerance</i>
mm	g/m	g/m
8.00	395	±5.9
7.00	302	±4.3
5.00	154	±3.1
4.00	98.9	±2.0
3.00	55.5	±1.5
2.50	38.5	±1.25

(*Page 6, clause 6.1*) — Add the following as Note 2 and renumber the existing note as Note 1:

'NOTE 2 — The Modulus of elasticity is to be taken as $205 \pm 10 \text{ kN/mm}^2$, unless otherwise indicated by the manufacturer.'

(*Page 6, clause 6.2*) — Delete 'Unless otherwise specified' from the beginning of this clause.

(*Page 8, clause 7.7*) — Delete 'If required by the purchaser' from the beginning of this clause.

(*Page 10, clause 8.3.4*) — Rewrite as follows:

'8.3.4 Ductility — In case one or more of the test pieces first selected fail to pass this test, twice the number of samples originally tested shall be selected for testing. All the samples so tested shall satisfy the requirement of this test. Should any of the test piece from these additional samples fail, the material represented by the samples shall be considered as not having complied with this standard.'

(*Page 10, clause 9.4, line 6*) — Delete 'if required'.

(*Page 11, clause 9.6*) — Add the following para at the end:

'It is necessary to protect the wires against damage and contamination during transport and storage. The coils of wire shall be packed as agreed to between the purchaser and the manufacturer.'