

**AMENDMENT NO. 1 OCTOBER 2015
TO
IS 15885 (PART 2/SEC 13) : 2012 SAFETY OF LAMP
CONTROLGEAR**

PART 2 PARTICULAR REQUIREMENTS

Section 13 d.c. or a.c. Supplied Electronic Controlgear for LED Modules

(Page 2, clause 6) — Substitute the following for the existing clause:

‘6 CLASSIFICATION

Control gear are classified according to the method of installation given in **6** of IS 15885 (Part 1) and according to protection against electric shock as,

- a) auto-wound controlgear;
- b) separating control gear;
- c) isolating control gear; and
- d) SELV control gear.’

(Page 3, clause 15, line 2) — Substitute ‘M-6’ for ‘L-6’ and ‘M-7’ for ‘L-7’.

(Page 3, clause 15.1, line 1) — Substitute ‘M-6’ for ‘L-6’.

(Page 3, clause 15.2, line 1) — Substitute ‘M-7’ for ‘L-7’.

(Page 4, Annex E) — Substitute the following for the existing:

‘The requirements of Annex E of IS 15885 (Part 1) shall apply only for windings of 50 Hz/60 Hz.’

(Page 5, Annex I) — Substitute the following for the existing:

‘The requirements of Annex M in IS 15885 (Part 1).’