

AMENDMENT NO. 6 OCTOBER 2025
TO
IS 15959 (PART 1) : 2011 DATA EXCHANGE FOR ELECTRICITY METER
READING, TARIFF AND LOAD CONTROL — COMPANION SPECIFICATION
PART 1 STATIC ENERGY METER

(Foreword, para 5) — Delete.

(Foreword, para 7) — Delete.

(Foreword, para 8) — Delete.

(Page 1, clause 1.2, line 2) — Substitute 'IS/IEC 62056' for 'DLMS/COSEM'.

(Page 1, clause 1.3, line 2) — Substitute 'IS/IEC 62056' for 'DLMS/COSEM'.

(Page 1, clause 1.3, line 4) — Substitute 'IS/IEC 62056' for 'DLMS/COSEM'.

[Page 1, clause 1.3(a)] — Substitute the following for the existing:

‘Interface classes, their instances, attributes and methods to be supported, event and status tables, identified objects, services, communication media and protocol stacks.’

[Page 1, clause 1.3(c)] — Substitute the following for the existing:

‘The necessary country/project specific codes are included in Annex A for specified usage of electricity meters’.

(Page 1, clause 3.3 and clause 3.4) — Substitute 'IS/IEC 62056-6-1 and IS/IEC 62056-6-2' for 'DLMS UA, Blue Book'.

(Page 2, clause 3.10) — Delete ‘, for example DLMS/COSEM’.

(Page 2, clause 3.13) — Delete.

(Page 2, clause 3.17) — Substitute 'IS/IEC 62056-42, IS/IEC 62056-46, IS/IEC 62056-4-7 and IS/IEC 62056-5-3' for 'DLMS UA, Green Book'.

(Page 3, clause 3.23) — Delete ‘also DLMS UA, Yellow Book and’.

(Page 4, Table 2, Note 1) — Substitute ‘4.8.2’ for ‘4.6.2’.

(Page 5, clause 5.4.1, line 1) — Substitute the following for the existing:

‘As per 4.2 of IS/IEC 62056-6-2, two referencing methods are provided to access the meter data, namely logical name (LN) referencing and short name (SN) referencing.’

(Page 5, clause 6) — Substitute ‘USAGE OF IS/IEC 62056 PROVISIONS’ for ‘USAGE OF DLMS/COSEM PROVISIONS’.

(Page 6, clause 7, line 1) — Substitute 'IS/IEC 62056' for 'DLMS/COSEM'.

(Page 7, clause 7.5.1, line 1) — Substitute 'IS/IEC 62056' for 'DLMS/COSEM'.

AMENDMENT NO. 6 TO IS 15959 (PART 1) : 2011

(Page 8, clause **8.1.1**, line 2) — Substitute the following for the existing:

‘The India-specific reference table, listing all possible events with corresponding identifiers, is defined in Annex G.’

(Page 8, clause **8.1.2**) — Substitute the following for the existing:

‘Value group E provides a flexible framework for classifying events into various categories according to specific requirements. This group currently supports 10 values (0...9), allowing users to define up to 10 distinct event categories.’

(Page 8, clause **8.2.3**, line 2) — Substitute the following for the existing:

‘Currently, 10 values (0...9) are supported for group E, allowing to define up to 10 event log categories, as specified in Table 11.’

(Page 9, clause **9.1**, line 1) — Substitute ‘IS/IEC 62056’ for ‘DLMS/COSEM’.

(Page 10, clause **11.1**, line 2) — Delete ‘in DLMS COSEM’.

(Page 10, clause **11.2.2**, line 2) — Substitute ‘IS/IEC 62056’ for ‘DLMS’.

(Page 10, clause **11.2.3**, line 4) — Substitute ‘IS/IEC 62056’ for ‘DLMS’.

(Page 15, clause **C-4**) — Substitute ‘IS/IEC 62056’ for ‘DLMS/COSEM’.

(Page 17, clause **D-3.1**) — Substitute ‘IS/IEC 62056’ for ‘DLMS/COSEM’.

(Page 20, clause **E-3.1**) — Substitute ‘IS/IEC 62056’ for ‘DLMS/COSEM’.

(Page 28, Annex H) — Delete the following standards from the list of referred Indian/International Standards:

‘DLMS UA 1000 -1 ed.9, 2009	Blue book, COSEM identification system and interface classes
DLMS UA 1000 -2 ed.7, 2007	Green book, DLMS/COSEM architecture and protocols
DLMS UA 1002: ed.1, 2003	White book, COSEM Glossary of terms
DLMS UA 1001 -1:2007 ed-3	Yellow book, companion testing process’

[Page 29, Annex J, clause **J-1.1 (a)**] — Delete ‘DLMS/COSEM’.

[Page 29, Annex J, clause **J-1.1 (e)**] — Substitute the following for the existing:

‘HHUs shall provide IS/IEC 62056 server interface to the BCS (Base Computer System — the Data collection software) over a suitable communication medium (local serial port implementing the IS/IEC 62056 HDLC layer stack is suggested).’

[Page 29, Annex J, clause **J-1.1 (g)**] — Substitute ‘IS/IEC 62056’ for ‘DLMS/COSEM’.

(Page 29, Annex K) — Substitute Annex K for the existing:

AMENDMENT NO. 6 TO IS 15959 (PART 1) : 2011

K-1 Meters claiming conformance to this specification shall be required to:

- a) conform to the base standards IS/IEC 62056 (Parts 21, 42, 46, 47, 53, 61 and 62) as certified by any suitably validated verification tool; and
- b) conform to the specific requirements and constraints of this standard; as certified by any accredited laboratory having facilities for the purpose.

K-2 This certification shall ensure:

- a) all mandatory parameters applicable to the category of the meter under test are implemented;
- b) all data types where specified are conforming to this document;
- c) all application associations are implemented as specified in this standard with all specified services supported;
- d) association object lists conform to this document with access rights and OBIS codes as specified here; and
- e) event related objects are implemented with event identifiers as specified in the event reference tables in this standard.

NOTE — For validation of verification and compliance tool, the technical guide shall be followed. Standard for Technical Guide is under development, until such time this note shall be in abeyance.’

(Page 33, Annex M) — Delete the following acronyms/abbreviations and description from the list:

‘DLMS	Device language message specification
DLMS UA	Device language message specification user association
CTT	Conformance test tool’