

AMENDMENT NO. 3 JANUARY 2016
TO
IS 15959 : 2011 DATA EXCHANGE FOR ELECTRICITY METER READING,
TARIFF AND LOAD CONTROL — COMPANION SPECIFICATION

(First cover page, IS Designation) — ‘Substitute 15959 (Part 1): 2011’ for ‘IS 15959 : 2011’ and wherever, it appears in the standard.

(First cover page 1, Hindi Title) — Insert the following title below the main Hindi title:
‘भाग 1 स्थैतिक ऊर्जा मीटर’

(First cover page 1, English Title) — Insert the following title below the main English title :
‘Part 1 Static Energy Meter’

[Page 1, clause 1.3 c)] — Insert the following at the end:

‘d) For requirements of data exchange for smart meters [see IS 15959 (Part 2) : 2016 Data exchange for electricity meter reading, tariff and load control — Companion specification for smart meters].’

[Page 5, Table 3, Sl No. (v), col 4] — Insert the following: ‘Get, Set, Get with block transfer, selective access’.

‘NOTE — Programmability is applicable only for meter with RS 485 ports. Hence, in MR mode ‘Set’ is applicable only for RS 485 meter.’

[Page 13, Table 21, Sl No. iii), col 2 and col 3] — Substitute the following for the existing:

Sl No.	Server Category	Metering Nomenclature/Purpose	Ref to, Annex
(1)	(2)	(3)	(4)
iii)	C1	HT (PT/CT operated) and LT (CT operated) consumer meters	—
iv)	C2	3 Phase 4 Wire Whole current/Direct connected consumer meters	—
v)	C3	Single phase whole current consumer metering	B

[Page 16, Table 22, Note 10 (see also Amendment No.1)] — Substitute following for the existing note:

‘10 The RTC — Time format by default shall be hh:mm:ss.

(Page 17, Table 23, Note 7] — Insert the following new Notes after Note 7:

‘8 The RTC — Time format by default shall be hh:mm.

9 Energy related parameters shall be verified at UPF, 0.5 lag and 0.8 lead’.

(Page 18, Table 24, Note 10, see also Amendment No.1) — Substitute the following for the existing note:

‘10 The RTC — Time format by default shall be hh:mm:ss.

[Page 19, Table 25, Sl No. (iv), col 2] — Substitute ‘ V_{YN}/V_{YB} ’ for ‘ V_{YN} ’.

[Page 19, Table 25, Sl No. (v), col 2] — Substitute ‘ V_{BN}/V_{BR} ’ for ‘ V_{BN} ’.

Amendment No. 3 to IS 15959 : 2011

[Page 19, Table 25, Note 7] — Insert the following new Notes after Note 7:

- ‘8 The RTC — Time format by default shall be hh:mm.
- 9 V_{RN} , V_{YN} and V_{BN} are for 3 ϕ /4W meter and V_{RY} and V_{BY} are for 3 ϕ /3W meter.
- 10 Active Energy related parameters shall be verified at UPF, 0.5 lag and 0.8 lead.’

[Page 19, Table 26, Note 7 (see also Amendment No. 1)] — Substitute the following for the existing note:

- ‘7 The RTC — Time format by default shall be hh:mm.’

[Page 21, Table 27, Sl No. (xvii), col 5] — Substitute ‘3’ for ‘37’.

[Page 21, Table 27, Note 11 (see also Amendment No.1)] — Substitute the following for the existing note:

- ‘11 The RTC — Time format by default shall be hh:mm:ss.’

(Page 22, Table 28, Note 6) — Insert the following new notes after Note 6:

- ‘7 The parameter current I_V is not applicable for 3 ϕ / 3W meter.
- 8 The RTC-time format by default shall be hh:mm.
- 9 Energy related parameters shall be verified at UPF, 0.5 lag and 0.8 lead.’

[Page 23, Table 29, Line No. 2 (see also Amendment No. 2)] – Substitute ‘Total power ON duration, in min’ for ‘Billing Power ON duration in minutes (During billing period).’

[Page 23, Table 29, Note 5 (see also Amendment No.1)] — Substitute the following for the existing note:

- ‘5 The RTC — Time format by default shall be hh:mm.’

(Page 23, Table 30] — Insert the following item after Sl No. iv) and renumber the existing Sl. No. v), vi) and vii) into vii), viii) and ix):

Sl No.	Parameter	OBIS CODE						Interface Class
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
v)	Category	0	0	94	91	11	255	1
vi)	Current rating	0	0	94	91	11	255	1

(Page 23, Table 30) — Substitute the following note for the existing note:

NOTE- 1 For Sl No. (iv),

- ‘Value of ‘0’ indicates 3P-3W HT CT PT meters;
- Value of ‘1’ indicates 3P-4W meters (applicable for already supplied meters);
- Value of ‘2’ indicates 3P 4W HT PT/CT meters;
- Value of ‘3’ indicates 3P 4W LT CT meters;
- Value of ‘4’ indicates 3P 4W whole current meters’

2 For Sl No. (v),

- ‘C1 indicates HT (PT/CT operated) and LT (CT operated) consumer meters.
- C2 indicates 3 Phase 4 Wire Whole current/Direct connected consumer meters.
- A indicates category A meter.
- B indicates category B meter’.

3 For Sl No. (vi), the Current rating shall be represented as I_b - I_{max} A.

[Page 24, Table 31, Note 6 (see also Amendment No. 1)] — Substitute the following the existing note:

- ‘6 The RTC — Time format by default shall be hh:mm:ss.’

Amendment No. 3 to IS 15959 : 2011

[(Page 27, Table 39, Sl No. (ii), col 7] — Substitute ‘e’ for ‘0’.

[Page 27, Table 39, Sl No. (ii), col 7] — Insert a new note 9:

‘9 e range from 0 to 6.

[Page 27, Table 39, Note 8 (see also Amendment No. 1)] — Substitute the following the existing note:

‘8 The RTC — Time format by default shall be hh:mm.’

[Amendment No. 2, Page 3, (clause E-11.1, Line No. 2 and 7)] — ‘Substitute e range from 1 to 5 for e range from 0 to 4’.

[Amendment No. 2, Page 5, Table 29 (see also Amendment No.1)] — ‘Insert the following (E-12 & E-12.1) after Line No.2.

[Amendment No. 2, Page 5, Clause E-12 (see also Amendment No.1)] — Insert ‘The capture objects of this daily load profile are as per Table 57’ after 7.

[Amendment No. 2, Page 7, Table 46, Sl No. (xv), col 2] — Substitute Total power ON duration in minutes with ‘Billing Power ON duration in Minutes (During billing period)’ for Total power ON duration in minutes.

(Amendment No. 2, Page 9, Table 52) — Substitute Note 2 ‘For each of the events a certain list of parameters shall be captured as per Table 54’ for the existing.

(Amendment No. 2, Page 10, Table 53) — Delete ‘Note 3’.

(Amendment No.2, Page 10, Table 54, Sl No. (ii), col 7) — Substitute ‘e’ for ‘0’.

(Amendment No.2, Page 10, Table 54, Note 3) — Insert note no. 4 ‘for Sl. No. (ii), col 7, e range from 1 to 5’.

(Amendment No. 2, Page 11, Table 56) — Substitute (Clause E-5.1, E-5.2 and E-5.3) for the existing Clause E-5.1.

(Amendment No. 2, Page 11, Table 57) — Substitute ‘(Clause E-12 and E-12.1)’ for Clause E-12.1.