

AMENDMENT NO. 4 APRIL 2017
TO
IS 15959 (PART 1) : 2011 DATA EXCHANGE FOR
ELECTRICITY METER READING, TARIFF AND LOAD
CONTROL — COMPANION SPECIFICATION

PART 1 STATIC ENERGY METER

[Page 23, Table 29, line No. 2 (see also Amendment No. 3, page 2)] —
Substitute ‘with’ for ‘for’.

[Page 23, Table 30, Sl No. (vi), col 7 (see also Amendment No. 3, page 2)]
— Substitute ‘12’ for ‘11’.

(Page 3, clause 4.2) — Substitute ‘Category C3 meter (server) shall support at least one communication port as given at P2 below. All other categories of meters shall support a minimum of two ports for data communication as per P1 and P2 below :’ for ‘The meter (server) shall support a minimum of two ports for data communication, as given below.’

[Page 29, clause K-2, Table 43 (see also Amendment No. 2)] — Insert the following new Note after Note 7:

‘8 Minimum parameters that the meter should have are i, ii, iii, iv, v, vi, viii, ix, xi, xiii, xiv, xv and xvi. The other parameters mentioned in the table are optional for buyers/utilities to choose.’

[Page 29, clause K-2, Table 44 (see also Amendment No. 2)] — Insert the following new Note after Note 7:

‘8 Minimum parameters that the meter should have are i and iii. The other parameters mentioned in the table are optional for buyers/utilities to choose.’

[Page 29, clause K-2, Table 45 (see also Amendment No. 2)] — Insert the following new Note after Note 3:

Amendment No. 4 to IS 15959 (Part 1) : 2011

‘4 Minimum parameters that the meter should have are i and ii. The other parameters mentioned in the table are optional for buyers/utilities to choose.’

[Page 29, clause **K-2**, Table 46 (*see also Amendment No. 2*)] — Insert the following new Note after Note 5:

‘6 Minimum parameters that the meter should have are i, iii, xiii and xv. The other parameters mentioned in the table are optional for buyers/utilities to choose.’