

AMENDMENT NO. 1 DECEMBER 2014
TO
IS 16018 : 2012 WHEELED FIRE EXTINGUISHERS —
PERFORMANCE AND CONSTRUCTION —
SPECIFICATION

(Foreword, para 3) — Insert the following at the end of para 3:

‘The following standards shall be withdrawn with the implementation of this standard:

<i>IS No.</i>	<i>Title</i>
2878 : 2004	Specification for fire extinguisher, carbon dioxide type (portable and trolley mounted) (<i>third revision</i>)
8149 : 1994	Functional requirements for twin CO ₂ fire extinguishers (trolley mounted) (<i>first revision</i>)
10658 : 1999	Specification for higher capacity dry powder fire extinguisher (trolley mounted) (<i>first revision</i>)
13385 : 1992	Specification for fire extinguisher — 50 litre capacity wheel mounted water type (gas cartridge)
13386 : 1992	Specification for fire extinguisher 50 litre capacity mechanical foam type

(Page 3, clause 5.3) — Substitute the following for the existing clause:

‘5.3 Fill Density

The fill density for carbon dioxide wheeled fire extinguishers shall not exceed 0.667 kg/l.

The fill density for clean-agent wheeled fire extinguishers shall be given by manufacturer of clean agent’

NOTE — These fill densities may be modified subject to national pressure vessel regulations.

Price Group 1

Amendment No. 1 to IS 16018 : 2012

[Page 3, clause 5.5.1 (d)] — Delete ‘4.5 kg’

(Page 3, clause 6.1) — Substitute the following for the existing clause:

6.1 Operating Temperatures

Wheeled fire extinguishers shall be capable of operating reliably within one of the following temperature changes:

a) +5°C to +55°C

b) –5°C to +55°C

NOTE — For specific requirements, manufacturer shall declare temperature range.’

(Page 3, clause 6.2.1.1) — Substitute the following for the existing clause:

‘6.2.1.1 The effective discharge time of wheeled fire extinguishers shall not be less than 30 s except Co₂ fire extinguisher for which it shall not be less than 15 s.’

(Page 3, clause 6.2.1.2) — Delete.

(Page 3, clause 6.2.1.3) — Delete.

(Page 4, clause 6.2.2.2, line 2) — Substitute ‘27 ±5 °C’ for ‘27 ±2 °C’.

(Page 4, clause 6.3.2) — Delete.

[Page 4, clause 6.4.1 (c), line 6] — Substitute ‘27 ±5 °C’ for ‘27 ±2 °C’.

(Page 4, clause 6.4.2, line 5) — Substitute ‘27 ±5 °C’ for ‘27 ±2 °C’.

(Page 5, clause 6.5.1, line 2) — Substitute ‘27 ±5 °C’ for ‘27 ±2 °C’.

(Page 5, clause 6.5.1, lines 3 and 6) — Substitute ‘5 s’ for ‘1 s’.

(Page 5, clause 6.6.1, line 2) — Substitute ‘5 days’ for ‘240 h’.

Amendment No. 1 to IS 16018 : 2012

(Page 5, clause **6.6.2**, lines 3 and 8) — Substitute ‘one’ for ‘eight’.

[Page 5, clause **6.7.2** (a)] — Substitute the following for existing:

‘a) Pushing or pulling the trailer mounted fire extinguisher at the rate of 8 km/h to 13 km/h over a rough surface.’

(Page 6, clause **6.7.2**, Note 1) — Delete.

(Page 6, clause **7.1.2**, line 3) — Substitute ‘7.2’ for ‘7.3’.

(Page 6, clause **7.1.4**, line 2) — Substitute ‘7.3’ for ‘7.4’:

(Page 6, clauses **7.2** and **7.3**) — Substitute the following for existing clauses and renumber the subsequent clause:

‘7.2 Class A, Class B and Class C Fire Test

Wheeled fire extinguisher intended for use shall be tested for the following fire rating system specified in IS 15683 for portable fire extinguishers:

a) Water based extinguisher – 4A, Min

b) Foam based extinguisher – 4A and 34 B, Min

c) Powder based extinguisher:

1) 25 kg – 2A and 34B, *Min*

2) 50 kg – 3A and 34B, *Min*

3) 75 kg – 4A and 34B, *Min*

d) Clean agent extinguisher:

10 kg – 1A and 21B, *Min*

20 kg – 2A and 34B, *Min*

30 kg and 50 kg – 3A and 34B, *Min*

Amendment No. 1 to IS 16018 : 2012

e) CO₂ based extinguisher:

- 1) 6.5kg and 9 kg – 13B, *Min*
- 2) 22.5kg and 45kg – 34B, *Min*

(Page 7, clause **8.3**, line 3) — Substitute ‘27 ±5 °C’ for ‘27 ±2 °C’.

(Page 7, clause **8.3.1.1**, line 1) — Substitute ‘water’ for ‘a suitable liquid’.

(Page 7, clause **8.3.3**) — Substitute the following for existing clause:

‘**8.3.3 Pressure Cycling Test**

One cylinder of each size and type shall sustain, without rupture, 100 cycles from zero to the test pressure (PE) and back to zero at the rate of 3 cycles/min. At the conclusion of testing, the cylinder shall be subjected to the burst test as specified in **8.3.1**.’

[Page 10, clause **8.11.3** (a) and (b)] — Substitute ‘27 ±5 °C’ for ‘27 ±2 °C’.

(Page 10, clause **8.12.1**, para 4 line 3) — Substitute ‘27 ±5 °C’ for ‘27 ±2 °C’.

(Page 13, clause **8.16.9**) — Insert the following new Note at the end of clause:

‘NOTE — Alternatively, manufacture’s test certificate for plastic components and pressure gauge is acceptable.’