

AMENDMENT NO. 1 NOVEMBER 2018
TO
IS 16205 (Part 1) : 2017 CONDUIT SYSTEMS FOR CABLE
MANAGEMENT

PART 1 GENERAL REQUIREMENTS

(Second cover page, Foreword, para 2) — Insert the following after para 2:

‘This standard is to be used in conjunction with the appropriate parts of this standard, which contain clauses to supplement or modify the corresponding clauses in Part 1 to provide the relevant particular requirements for each type of product.’

(Page 3, clause 6.4.2) — Substitute ‘IS/IEC 60529’ for ‘IS 12063’.

(Page 5, Table 3) — Substitute ‘(Clauses 9.3 and 9.4)’ for ‘(Clause 9.4)’.

(Page 8, clause 11.3.1.4, line 5) — Substitute ‘100 MΩ’ for ‘100 M’.

(Page 8, clause 11.3.2.2, line 5) — Substitute ‘lead shot’ for ‘lead spheres’.

(Page 10, clause 14.1.1, para 2) — Substitute the following for the existing:

‘Compliance is checked by the tests given in 14.1.2 and 14.1.3.’

(Page 10, clauses 14.1.2.1 and 14.1.3.1) — Substitute the following for the existing:

‘An assembly is made of conduit and conduit fittings using all conduit entries. Wherenecessary, any open ends of the assembly are plugged, or are not part of the test.’

(Page 10, clauses 14.1.2.1 and 14.1.2.2, line 1) — Delete the words ‘is made of’.

(Page 10, clause 14.2.2.2, para 2, lines 2 and 3) — Substitute ‘[K₃Fe(CN)₆]’ for ‘[K₃Fe(CN)₆]’ and ‘[(NH₄)₂S₂O₈]’ for ‘[(NH₄)₂S₂O₈]’.

(ETD 14)