

AMENDMENT NO. 1 NOVEMBER 2023

TO

**IS 16246 : 2015 ELASTOMER INSULATED CABLES WITH LIMITED CIRCUIT
INTEGRITY WHEN AFFECTED BY FIRE — SPECIFICATION**

(Page 2, clause **10.1**) — Substitute the following for existing:

‘10.1 The conductor shall be of either solid, complying with Class 1 or stranded construction, complying with Class 2 of IS 8130’.

[(Page 6, Table 1, *Sl No.* v), b), *col* (2)] — Substitute ‘Ageing in air bomb’ for ‘Ageing in air oven’.

[(Page 6, Table 1, *Sl No.* v)] — Insert the following at the end:

Sl No.	Tests	Requirements, Ref to	Method of Test to Part of IS 10810
(1)	(2)	(3)	(4)
v)	h) Oil resistance test	-do-	Part 31

[(Page 6, Table 2, *Sl No.* v)] — Delete.

[(Page 6, Table 2, *Sl No.* viii)] — Substitute the following for the existing:

Sl No.	Test	Requirement
(1)	(2)	(3)
viii)	Ageing in air bomb	
	a) Temperature	127 ± 1 °C
	b) Duration	40 h
	c) Pressure	0.55 ± 0.02 MPa
	d) Tensile strength, variation	± 50, <i>Max</i>
	e) Elongation at break, variation	± 50, <i>Max</i>