

**AMENDMENT NO. 2 NOVEMBER 2011
TO
IS 1003 (Part 1) : 2003 TIMBER PANELLED AND
GLAZED SHUTTERS — SPECIFICATION**

PART 1 DOOR SHUTTERS

(Fourth Revision)

(Page 1, clause 5.3) — Substitute the following for the existing:

‘Blockboards used for panelling of door shutters shall conform to BWP grade of IS 1659.’

(Page 2, clause 5.9) — Insert the following new clauses after the clause:

‘5.10 Bamboo Mat Board

Bamboo mat board used for panelling of door shutters shall conform to IS 13958.

5.11 Bamboo Mat-Veneer Composite

Bamboo mat-veneer composite for panelling of door shutters shall conform to IS 14588.

5.12 Laminated Veneer Lumber

Laminated veneer lumber used for rails and stiles shall conform to IS 14616.

5.13 Prelaminated Medium Density Fibre Board

Prelaminated medium density fibre board used for panelling of door shutters shall conform to Grade I, Type I of IS 14587.

5.14 Wire Gauze

Wire gauze used for panels shall conform to IS 1568.’

(Page 2, clause 6.1, first sentence) — Substitute the following for the existing:

Amend No. 2 to IS 1003 (Part 1) : 2003

‘Timber panelled shutters shall be constructed in the form of timber or laminated veneer lumber framework of stiles and rails with panel inserts of timber, plywood, blockboard, medium density fibreboard, veneered particle board, asbestos cement sheets, prelaminated particle board, bamboo mat board, bamboo mat-veneer composite, prelaminated medium density fibre board, wire gauze or glass.’

(Page 4, clause 6.3) — Substitute the following for the existing:

‘Stiles, top rails, bottom rails and lock rails of shutters shall be made of one piece of timber or of laminated veneer lumber only. Intermediate rails, lock rails and bottom rails exceeding 150 mm in width may be made out of one or more pieces of timber or laminated veneer lumber, but the width of each piece shall be not less than 75 mm. Where more than one piece of timber or laminated veneer lumber is used, they shall be joined with a continuous tongued and grooved joint glued together and reinforced with metal dowels at regular intervals not exceeding 200 mm or pinned to the full thickness of the door with wooden/bamboo pin. Jointed pieces of timber shall belong to the same specie.’

(Page 6, clause 6.14) — Insert the following after the clause and renumber the subsequent clauses:

‘6.15 Bamboo Mat Board Panelling

Panels shall be made up of one piece of bamboo mat board. The thickness of the boards used shall not be less than 12 mm.

6.16 Bamboo Mat-Veneer Board Panelling

Panels shall be made up of one piece of bamboo mat-veneer board. The thickness of the boards used shall not be less than 12 mm.

6.17 Prelaminated Medium Density Fibre Board Panelling

Panels shall be made up of one piece of prelaminated medium density fibre board. The thickness of the boards used shall not be less than 12 mm.’

Amend No. 2 to IS 1003 (Part 1) : 2003

(Page 12, Annex A) — Substitute the following for the existing entries:

<i>IS No.</i>	<i>Title</i>
'848 : 2006	Synthetic resin adhesives for plywood (phenolic and aminoplastic) — Specification (<i>second revision</i>)
1659 : 2004	Blockboards — Specification (<i>fourth revision</i>)
3087 : 2005	Particle boards of wood and other lignocellulosic materials (medium density) for general purposes — Specification (<i>second revision</i>)
3097 : 2006	Veneered particle boards — Specification (<i>second revision</i>)
4351 : 2003	Steel door frames — Specification (<i>second revision</i>)'

(Page 12, Annex A) — Add the following new entries at the appropriate place:

<i>IS No.</i>	<i>Title</i>
'1568 : 1970	Specification for wire cloth for general purposes (<i>first revision</i>)
13958 : 1994	Bamboo mat board for general purposes — Specification
14587 : 1998	Prelaminated medium density fibre board — Specification
14588 : 1999	Bamboo mat-veneer composite for general purposes — Specification
14616 : 1999	Laminated veneer lumber — Specification'

(CED 11)