

AMENDMENT NO. 2 JANUARY 2017
TO
IS 1180 (PART 1) : 2014 OUTDOOR/INDOOR TYPE OIL IMMERSSED
DISTRIBUTION TRANSFORMERS UPTO AND INCLUDING 2 500 kVA, 33kV —
SPECIFICATION

PART 1 MINERAL OIL IMMERSSED

(Fourth Revision)

(Foreword, para 3, line 3) — Substitute ‘100 kVA’ for ‘25 kVA’.

(Foreword, para 5, line 5) — Substitute ‘100 kVA’ for ‘25 kVA’.

[Page 1, clause 1(c)] — Substitute the following for the existing:

‘c) Single phase ratings up to and including 100 kVA sealed type.’

(Page 5, clause 8) — Substitute the following for the existing:

‘8 TECHNICAL PARAMETERS OF SINGLE PHASE DISTRIBUTION TRANSFORMERS UPTO AND INCLUDING 100 kVA (SEALED TYPE)’

[Page 6, clause 9.1 (b)] — Substitute the following for the existing :

‘b) Amorphous core material (*see* IS 16585).’

(Page 8, clause 15.2.1, para 3) — Substitute the following for the existing para:

‘For single phase transformers up to 100 kVA, the transformer tank shall be of robust construction round in shape and shall be capable of withstanding a pressure of 100 kPa and a vacuum of 760 mm of mercury.’

(Page 15, clause 21.5.3) — Substitute the following for the existing clause:

‘21.5.3 For Single Phase Distribution Transformers Upto and Including 100 kVA’.

(Page 15, Annex A) — Insert the following reference at the appropriate place:

<i>IS No.</i>	<i>Title</i>
16585 : 2016	Magnetic materials — Specification for individual materials — Fe-based amorphous strip delivered in the semi-processed state

[Page 18, Annex E, clause E-2(a) (see also Amendment No. 1)] — Substitute ‘Tank without corrugations’ for ‘Tank with corrugations’.

[Page 18, Annex E, clause E-2(b) (see also Amendment No. 1)] —Substitute ‘Tank with corrugations’ for ‘Tank without corrugations.’