

Our Ref: CMD III/16:9523


Date: 11/10/2010.

Subject: Implementation of Amendment No.2 issued to IS 9523: 2000 – Ductile Iron Fittings for Pressure Pipes for Water. Gas & Sewage

Amendment No. 2 October 2010 to IS 9523: 2000 has been published (copy enclosed). This amendment does not require any change in the existing STI (Doc:STI/9523/1 September 2000).


It has been decided to implement this amendment with immediate effect. ROs/BOs are requested to inform the licensees under their jurisdiction about implementation of the amendment and ensure compliance.

Encl: as above



(Ashok Narula)

Director & Scientist -E (CMD 3)

Scientist-F & HEAD(CMD3)

All ROs/BOs/CMD-1/ BIS LabsCopy to: ITS – for putting the circular on INTRANET immediately.MTD – for arranging necessary Gazette Notification

CMD III

**AMENDMENT NO. 2 OCTOBER 2010
TO
IS 9523 : 2000 DUCTILE IRON FITTINGS FOR PRESSURE
PIPES FOR WATER, GAS AND SEWAGE —
SPECIFICATION**

(First Revision)

* (Page 4, clause 11.2) — Add the following new clause after 11.2:

‘11.3 When, by agreement between the manufacturer and the purchaser, fittings with different shapes, lengths and combinations of diameters than those given in Tables 15 to 31 are supplied according to this standard, they shall comply with thicknesses, nominal sizes, external diameters and flange dimension as specified in 5, 11 and Tables 3 to 7 and all other requirements of this standard.’

(MTD 6)

H (CMD III) 

 6/110  

Reprography Unit, BIS, New Delhi, India