

AMENDMENT NO. 4 DECEMBER 2016
TO
IS 9523 : 2000 DUCTILE IRON FITTINGS FOR PRESSURE
PIPES FOR WATER, GAS AND SEWAGE —
SPECIFICATION

(First Revision)

(Page 5, Table 4, Note 2) — Substitute the following for the existing Note:

‘2 Dimension ‘s’ is for guidance only.’

(Page 5, Table 4, Note 2) — Insert the following new Note:

‘3 Flanged dimension may be allowed as per customer specification and it shall not be less than PN 10 thickness.’

(Page 6, Table 5, Note 2) — Substitute the following for the existing Note:

‘2 Dimension ‘s’ is for guidance only.’

(Page 6, Table 5, Note 2) — Insert the following new Note:

‘3 Flanged dimension may be allowed as per customer specification and it shall not be less than PN 10 thickness.’

(Page 7, Table 6, Note 2) — Substitute the following for the existing Note:

‘2 Dimension ‘s’ is for guidance only.’

(Page 7, Table 6, Note 2) — Insert the following new Note:

‘3 Flanged dimension may be allowed as per customer specification and it shall not be less than PN 10 thickness.’

(Page 8, Table 7, Note 2) — Substitute the following for the existing Note:

‘2 Dimension ‘s’ is for guidance only.’

(Page 8, Table 7, Note 2) — Insert the following new Note:

‘3 Flanged dimension may be allowed as per customer specification and it shall not be less than PN 10 thickness.’