

AMENDMENT NO. 1 JULY 1995
TO
IS 9537 (Part 1) : 1980 SPECIFICATION FOR
CONDUITS FOR ELECTRICAL INSTALLATIONS
PART 1 GENERAL REQUIREMENTS

(*Page 11, clause 9.4.2*) — Substitute the following for the existing matter:

'9.4.2 The sample shall be kept inside the deep freezer the temperature of which is maintained at $- 5 \pm 2^{\circ}\text{C}$.

When the samples have attained the temperature of the air within the freezer or after 2 h, whichever is longer period, each sample shall be in turn placed in position on the steel base as shown in Fig. 2 immediately within 15 s after the removal from the deep freezer. The hammer is immediately allowed to fall whereby an impact energy J according to Table 2 is applied. The mass of the hammer and the height of the fall are also specified in Table 2.'

(ETD 14)

Printed at Simco Printing Press, Delhi, India