

AMENDMENT NO. 1 APRIL 1984
TO
IS:9537(Part 2)-1981 SPECIFICATION FOR CONDUITS
FOR ELECTRICAL WIRING
PART 2 RIGID STEEL CONDUITS

Addendum

(Page 12, clause 9.3.1) - Add the following new clause after 9.3.1:

'9.3.2 The difference between the initial diameter and the diameter of the flattened sample shall not exceed 10 percent.'

(ETDC 44)

Reprography Unit, BIS, New Delhi, India