

AMENDMENT NO. 2 MAY 1990
TO
IS : 9537 (Part 2) - 1981 SPECIFICATION FOR
CONDUITS FOR ELECTRICAL WIRING

PART 2 RIGID STEEL CONDUITS

(*Page 6, clause 7.1, second sentence*) — Insert the words 'or as agreed to between the purchaser and the supplier' after the words '3 to 5 metres'.

(*Page 12, clause 9.3.1*) — Substitute the following for the existing clause:

'9.3.1 The relevant provision of 9.3 of IS : 9537 (Part 1)-1980* shall apply except that the sample shall not be conditioned at a temperature of $27 \pm 2^{\circ}\text{C}$ for 10 hours.'

*Specification for conduits for electrical installations: Part 1 General requirements.

(ETDC 14)

Reprography Unit, BIS, New Delhi, India