



AMENDMENT NO. 1 JULY 1984

TO

IS : 9556-1980 CODE OF PRACTICE FOR DESIGN AND CONSTRUCTION OF DIAPHRAGM WALLS

(Page 4, clause **2.4**, lines 2 and 3) — Substitute ' machines ' for ' methods ' and ' 800 ' for ' 200 '.

(Page 4, clause **2.6**, line 2) — Substitute ' or boring tool ' for ' equipment '.

(Page 6, clause **4.3**, line 1) — Delete the words ' consisting of 50 percent coarse sand '.

(Page 7, clause **4.6.2**) — Add the following clause after **4.6.2**:

‘4.6.3 Reinforcement in each panel should form a cage and the vertical ends of the cage should match with the type of joints of the panel. For ease of handling and good workmanship, the cage should be made rigid. Clear distance between reinforcement bars should not be less than 100 mm for easy flow of concrete.’

(Page 7, clause **4.7**) — Add the following new matter at the end:

‘ for method other than tremie ’.

(Page 7, clause **5.1**, lines 6, 7 and 8) — Substitute ' with kelly bars ' for ' grabs with Kelly bars ' add the word ' winch ' after ' crane ' and substitute ' motor ' for ' mortar ' respectively.

(Page 8, clause **5.4**, line 8) — Substitute ' rig ' for ' ring '.

(Page 9, clause **7.1**, line 1) — Add the word ' based ' after ' sodium '.

(Page 9, clause **7.1**) — Add the following clause after clause **7.1**:

‘7.1.1 For proper stabilisation of the trench walls by bentonite slurry, it is essential to allow adequate geletion period for bentonite slurry. For this purpose after slurry is mixed thoroughly it should not be used for a period of minimum 12 h.’

(Page 12, clause **8.1**, last two lines) — Substitute ' minimum 1.5 m ' for ' adequately '.

(Page 13, clause **9.2**) — Add the following new matter at the end:

‘ The top of the ground level shall be minimum 1.5 m above high water table. ’

(Page 15, clause **10.2.3**) — Add the following clause after **10.2.3**:

‘ **10.2.3.1** Circular cover blocks are considered essential to the reinforcement, so that they roll along the trench without damage and maintain adequate cover. ’

(Page 21, clause **10.7.2**, line 1) — Add ‘ (plastic concrete) ’ after ‘ clay concrete. ’

(BDC 43)