

AMENDMENT NO. 1 MAY 2025
TO
IS 14203 : 2023 FIRE RESISTING RECORD PROTECTION CABINETS —
SPECIFICATIONS
(Third Revision)

(Page 1, clause 3) — Substitute the following for the existing:

‘3 NOMINAL SIZES

Nominal sizes of the cabinet shall be denoted by its internal height as specified in Table 1. Or any other size which is mutually agreed between the purchaser and the supplier.’

(Page 1, table 1) — Insert the note in Table 1:

‘NOTE — Or any other cabinet(s) of size and height of pedestal which is mutually agreed between the purchaser and the supplier, provided that representative size is tested successfully as mentioned in **11**.’

(Page 1, clause 4) — Substitute the following for the existing:

‘Record protection cabinets shall be of four types as follows:

- a) FR30 — Cabinets having a fire resisting rating of 30 min;
- b) FR60 — Cabinets having a fire resisting rating of 60 min.
- c) FR90 — Cabinets having a fire resisting rating of 90 min; and
- d) FR120 — Cabinets having a fire resisting rating of 120 min.’

(Page 2, clause 8.2, line 8) — Insert the following at the end:

‘Alternately the locking mechanism can be of different design as type tested and successfully passed.’

(Page 2, clause 8.3) — Substitute the following for the existing:

‘The cabinet shall be supplied with a key lock(s)/combination lock(s)/electronic lock(s) having minimum 10,000 combinations. The keys shall be made of stainless steel or any other non-ferrous metal/alloy having non-corrosive properties. Minimum two sets of the keys shall be supplied. Alternatively, any combination of key lock, combination lock or electronic lock may be provided, if required by the purchaser.’

(Page 2, clause 11.1, line 8) — Insert the following at the end:

‘With test of type tested size, the lower sizes upto 50 percent of internal volume are covered, provided that cabinet differs only in size, and not in such details as number of doors, plinth size, type and thickness of construction and protective materials, wall and door thickness, locking mechanism, hinge construction, rabbet geometry and any other feature that will affect fire protection.’

(MED 24)

Price Group 1
Publication, BIS, New Delhi