

AMENDMENT NO. 1 OCTOBER 2010
TO
IS 14255 : 1995 AERIAL BUNCHED CABLES —
FOR WORKING VOLTAGES UP TO AND INCLUDING
1 100 VOLTS — SPECIFICATION

(Page 1, clause 1.2) — Substitute the followings for the existing:

'1.2 The cables covered in this standard are suitable for use on single phase and three phase ac (earthed or unearthed) system for rated voltage up to and including 1 100 volts.'

(Page 3, clause 6.5) — Substitute the followings for the existing:

'6.5 The size of messenger conductor for single phase and three phase cable and its breaking load and maximum dc resistance shall be as per Table 3.'

(Page 4, clause 8.1) — Insert the following new clause 8.2 after 8.1 and renumber the subsequent clause:

'8.2 The single phase conductor shall be provided with 'One Ridge' and if neutral insulated conductor is provided shall have 'Four Ridges' as shown in Fig. 1 for quick identification. The Street Light Conductor & Messenger Conductor (if insulated) shall not have any identification mark.'

(Page 4, clause 9.1) — Insert the following new clause 9.2 after 9.1 and renumber the subsequent clause:

'9.2 Single insulated phase conductor, one insulated neutral conductor (if required) and a Street Lighting Conductor (if required) shall be twisted around the bare (or insulated) as required Messenger Conductor without filler with a lay not exceeding 35 times the diameter of the insulated phase conductor.'