

**AMENDMENT NO. 1 MARCH 2003
TO
IS 14665 (PART 4/SEC 9) : 2001 ELECTRIC TRACTION
LIFTS**

PART 4 COMPONENTS

Section 9 Controller and Operating Devices for Lifts

(*Page 33, clause 2.1*) — Substitute the following for the existing clause:

2.1 The stopping of the lift machine or stopping the main circuit shall be controlled as detailed below.

2.1.1 *Motor Supplied Directly from AC or DC Mains*

The supply to the motor shall be interrupted by two independent contactors, the contact of which shall be in series in the motor circuit.

2.1.2 *Drive Using a 'Ward-Leonard' System*

Two independent contactors shall interrupt the excitation of the generator.

2.1.3 AC or DC Motor supplied and controlled by static elements. One of the following methods shall be used:

- a) Two independent contactors shall interrupt the current to the motor.
- b) A System consisting of:
 - 1. A contactor interrupting the current in all the phases. The coil of the contactor shall be released at least before each change is direction. If the contactor does not release, any further movement of the lift shall be prevented.
 - 2. A control device blocking the flow of energy in the static elements.
 - 3. A monitoring device to verify the blocking of the flow of energy each time the lift is stationary.

If during a normal stopping period, the blocking of the flow of energy by the static elements is not effective, the monitoring device shall cause the contactor to release and any further movement of the lift shall be prevented.'

Amend No. 1 to IS 14665 (Part 4/Sec 9) : 2001

(*Page 33, clause 2.3*) — Substitute the following for the existing clause:

2.3 The interruption of the electrical safety chain or safety circuit shall stop and shall prevent the movement of the car. In the event of an earth fault with any door open, the lift shall not operate.'

(ET 25)