

AMENDMENT NO. 2 JANUARY 2021

TO

IS 14768 (PART 1) : 2000 CONDUITS FITTING FOR ELECTRICAL INSTALLATIONS — SPECIFICATION

PART 1 GENERAL REQUIREMENTS

(Page 1, clause 2) — Substitute the following for the existing:

‘2 REFERENCES

The following Indian Standards are necessary adjuncts to this standard:

<i>IS No.</i>	<i>Title</i>
9537 (Part 1) : 1980	Conduits for electrical installations: Part 1 General requirements
14772 : 2020	Boxes and enclosures for electrical accessories for household and similar fixed electrical installations — General requirements (<i>first revision</i>)
14763 : 2000	Conduits for electrical purposes outside diameters of conduits for electrical installation and threads for conduits and fittings
IS/IEC 60529: 2001	Degrees of protection provided by enclosures (IP Code)

(Page 3, clause 6.8.1.1, line 2) — Substitute ‘12.5 mm’ for ‘12 mm’.

(Page 3, clause 6.8.2.2) — Substitute the following for the existing:

‘6.8.2.2 Conduits fitting giving protection against vertically falling water drops when the enclosure is tilted up to 15° (IPX2).’

(Page 3, clause **6.8.2.3**, line 2) — Substitute ‘spraying’ for ‘splashing’.

(Page 3, clause **6.8.2.7**) — Substitute the following for the existing:

‘**6.8.2.7** Conduits fitting giving protection against the effects of temporary immersion in water (IPX7)’.

(Page 3, clause **6.8.2.8**) — Substitute the following for the existing:

‘**6.8.2.8** Conduits fitting giving protection against the effects of continuous immersion in water (IPX8)’.

(Page 9, clause **14.2**, para 2, line 4) — Substitute ‘IS/IEC 60529’ for ‘IS 12063’.

(Page 9, clause **14.3**, para 3, line 2) — Substitute ‘IS/IEC 60529’ for ‘IS 12063’.