

AMENDMENT NO. 1 JUNE 2004
TO
IS 14768 (PART 2) : 2003 CONDUIT FITTINGS FOR ELECTRICAL
INSTALLATIONS — SPECIFICATION
PART 2 METAL CONDUIT FITTINGS

(*Second cover page, para 4, line 1*) — Substitute 'IS 14768 (Part 1) : 2000' for 'IS 9537 (Part 1) : 1980 Conduit for electrical installations : Part 1 General requirements'.

(*Page 1, clause 2 Addition, col 1, Row 3*) — Substitute 'IS 9537 (Part 7) (Under preparation)' for 'IS 9537 (Part 7): 2001'.

(*Page 1, clause 8.3, para 1, line 2*) — Substitute 'Fig. 101 to Fig. 112' for 'Fig. 101 to Fig. 108'.

(*Page 1, clause 8.3, para 2, lines 1 and 2*) — Substitute '[see Fig. 105 to Fig. 108 of IS 14768 (Part 1)]' for ' [see 5.1 to 5.4 of IS 14768 (Part 1)]'.

(*Page 2, clause 8.3, last para*) — Delete.


[*Page 2, clause 101.1(d)*] — Delete.

[*Para 2, clause 101.2(c)*] — Delete.

(*Page 2, Fig. 101, Table, col 3, heading*) — Substitute '*F, Max*' for '*x, Max*'.

(*Page 7, Fig. 107, Table, col 3, heading*) — Substitute '*B Min*' for '*B Max*'.

(*Page 7, Fig. 108*) — Insert the following figures after Fig. 108:



All dimensions in millimeters.


Nominal Size of Tee	<i>l</i>	<i>r</i>
16	32	16
20	40	20
25	50	25
32	64	32
40	80	40
50	100	50
63	126	63

NOTE — Dimension *a* will be twice the sum of dimensions *l* and *r*.

Material : Steel
Screw threads in accordance with IS 14763.
The illustration is not intended to govern design, except for the dimensions shown.

FIG. 109 TEES

Amend No. 1 to IS 14768 (Part 2) : 2003




All dimensions in millimeters.								
Dimensions of Small Circular Boxes								
Size of Conduit	B	C	D	E	F	G	H	t
16	19.2	12.5	17.5	14.5 ± 1	28	60	50	1.6
20	23.2	14.5	20.0	17.0 ± 1	28	60	50	1.6
25	28.2	17.0	24	21.0 ± 1	31	60	50	1.6

Dimensions of Large Circular Boxes								
Size of Conduit	B	C	D	E	F	G	H	t
20	25	15.0	20	17 ± 1	35	80	70	2.5
25	30	17.5	24	21 ± 1	40	80	70	2.5
32	37	21.0	24	21 ± 1	40	80	70	2.5

Material : Steel
Screw threads in accordance with IS 14763.
The illustration is not intended to govern design, except for the dimensions shown.

FIG. 110 CIRCULAR BOXES

Amend No. 1 to IS 14768 (Part 2) : 2003



All dimensions in millimetres.

Preferred Internal Dimensions for Height, Length and Breadth of Rectangular Boxes

Height	Length	
37.5	75	75
	100	75
	100	100
	150	75
	150	100
	150	150
50.0	75	75
	100	75
	100	100
	150	75
	150	100
	150	150
75.0	100	100
	150	75
	150	100
	150	150
100.0	100	100
	150	150
150.0	100	100

Dimensions of Rectangular Boxes

Size of Conduit	B	C	D	E	t
20	25	15.0	20	17 ± 1	1.6
25	30	17.5	24	21 ± 1	1.6
32	37	21.0	24	21 ± 1	1.6


Material: Steel

Screw threads in accordance with IS 14763.

The illustration is not intended to govern design, except for the dimensions shown.

FIG. III RECTANGULAR BOXES

Amend No. 1 to IS 14768 (Part 2) : 2003



All dimensions in millimetres.

Nominal Size	G, Min	H, Min
16	1.6	1.6
20	1.6	1.6

NOTE — The two- and three-way holes may be arranged to this pattern.
Material : Steel
Screw threads in accordance with IS 14763.
The illustration is not intended to govern design, except for the dimensions shown.

FIG. 112 CIRCULAR LOOPING Boxes