

**AMENDMENT NO 1 MARCH 2009
TO
IS 14906 : 2001 AIR-CONDITIONING AND VENTILATION
OF WHEELHOUSE ON BOARD SHIPS — DESIGN
CONDITIONS AND BASIS OF CALCULATIONS**

(Page 1, clause 3.1) — Substitute the following for the existing:

‘3.1 Wheelhouse — Enclosed area of the bridge including adjoining area of radio room and other electronic equipment rooms.’

(Page 1, clause 4.1, Note) — Insert the following as Note 2 below the existing note which shall now be numbered as Note 1:

‘2 For the wheelhouse area with the radio room, electronic and communication equipment rooms etc, the heat load will be the guiding factor for deciding the cooling load and volumetric air displacement will be only secondary. However a guideline regarding the number of Air change may be mentioned for reference purpose only and may be applicable when only Wheelhouse is considered in isolation for smaller vessels.’

(Page 1, clause 5.1, Note 3) — Substitute ‘ $W/(m^2.k)$ ’ for ‘ $W (m^2.k)$ ’.

(Page 2, clause 6.2, line 1) — Insert the word ‘room’ in between ‘wheelhouse’ and ‘shall’.